

# Technical Specifications

## Contents

|  |          |
|--|----------|
| <b>1. Grid Connected Solar PV Components</b>       | <b>2</b> |
| 1.1 Solar Photovoltaic (PV) Module                 | 2        |
| 1.2 Weather Station                                | 4        |
| 1.3 Grid Connected Inverter                        | 10       |
| 1.4 Support Structure for PV Modules               | 12       |
| 1.5 Junction Box                                   | 15       |
| 1.6 Grid Connected AC Combiner Box                 | 17       |
| 1.7 AC Distribution Board                          | 20       |
| 1.8 Cables and Accessories                         | 22       |
| 1.9 Earthing System                                | 26       |
| 1.10 Lightning Protection System                   | 30       |
| 1.11 Monitoring System and Data Acquisition System | 33       |
| 1.12 Containerized System (Control Room)           | 35       |
| 1.13 Transformer                                   | 36       |
| 1.14 Earthing System for Transformer               | 39       |
| 1.15 Fire Fighting System                          | 41       |
| 1.16 Fencing                                       | 42       |
| 1.17 Design and Drawings                           | 43       |
| 1.18 System Operation and Maintenance              | 44       |
| 1.19 Project Information Board                     | 44       |
| 1.20 Spare Parts                                   | 45       |

## 1. Grid Connected Solar PV Components

The bidder must clearly response the technical specifications and standards asked for the system components in their technical proposal. The bidder must provide the data sheet and technical specifications of all the components including IV curve, efficiency curves, test certificates/reports, warranty certificate, international standards.

### 1.1 Solar Photovoltaic (PV) Module

The total required PV array capacity must be at least 500kWp. The PV modules shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model  |  |                                       |
| 2    | Manufacturer's experience in manufacturing PV modules:<br>At least 10 years  |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or ISO 14001:2015,<br>OHSAS 18001:2007 or<br>OHSAS 18001:2017//ISO 45001:2018<br>Certificates  |  |                                       |
| 4    | Peak Power of Individual Module at STC: At least 400 Watt-peak   |  |                                       |
| 5    | Array Capacity: At least 500kWp  |  |                                       |
| 6    | PV Module Efficiency: At least 20%   |  |                                       |
| 7    | Cell type: Mono Crystalline  |  |                                       |
| 8    | No. of Cells per Module: At least 72   |  |                                       |
| 9    | Power Tolerance: 0 to +3%  |  |                                       |
| 10   | Fill Factor: At least 75%  |  |                                       |
| 11   | The cable connected to the module junction box must be of copper multi-strand, PVC insulated and UV resistant and be provided with minimum cross section of 4mm <sup>2</sup> and length of at least 1 meter with PV connectors |  |                                       |
| 12   | Degree of Protection (Junction Box):<br>At least IP68 according to IEC 60529   |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 13   | The PV Connectors must be provided with degree of protection of at least IP68 according to IEC 60529. The PV connectors must comply with IEC 62852.  |  |                                       |
| 14   | Operating Temperature: Minimum range of -20°C to +50°C   |  |                                       |
| 15   | Nominal Module Operating Temperature: 42±3 °C  |  |                                       |
| 16   | System Voltage: At least 1000 VDC  |  |                                       |
| 17   | A letter provided by principal PV module manufacturer in their letter head stating the warranty period for their PV module.<br>Product Warranty: ≥ 10 years<br>Power Output Warranty:<br>First year: ≥ 97% of STC power<br>10 years: ≥ 90% of STC Power<br>25 years: ≥ 80% of STC Power and linear warranty ≤ 0.6% per year from year 2 and onwards  |  |                                       |
| 18   | Local Certification required:<br>RETS Certificate (PIT Certificate must be submitted with Bid and RST Certificate must be submitted before the installation)   |  |                                       |
| 19   | International Certification:<br>IEC 61215:2005 2nd Edition or IEC 61215-1:2016, IEC 61215-2:2016 or IEC 61215-1:2021, IEC 61215-2:2021, IEC 61730-1:2004 or IEC 61730-1:2016, IEC 61730-2:2004 or IEC 61730-2:2016 and IEC 62804-1:2015<br><br>The test certificates must be provided. The Test Certificates from IEC accredited independent laboratory must be provided. The PV Module must |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of PV Module Testing.     |  |                                       |
| 20   | The Datasheet and Name Plate Information of PV Module must comply as per EN 50380.  |  |                                       |
| 21   | The PV Module must comply as per IEC 60904.   |  |                                       |
| 22   | The manufacturer must have accreditation for conformity to ISO/IEC 17025 Standard. The document/certificate must be provided.   |  |                                       |
| 23   | All PV modules offered for the project must be of same type, same model, same power rating and from the same manufacturer.  |  |                                       |
| 24   | The PV modules must be packed in a box made from triple strength cardboard resting on a wooden or plywood Pallet. There must be at least 15mm spacing gap between the modules during the packaging. |  |                                       |
| 25   | The Bidder must submit the technical datasheet of PV Module and PV Connector.   |  |                                       |

## 1.2 Weather Station

The weather station along with the data logger shall be provided for adequate meteorological data to evaluate system performance and shall have capability of recording and storing data into the data logger. The weather station shall comply with following standards and technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in meteorological measurement system:<br>At least 5 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015 Certificate  |  |                                       |
| 4    | Pyranometer (Horizontal and Inclined)   |  |                                       |
|      | Type: Spectrally Flat Class A   |  |                                       |
|      | Output Range: 0 to 1600 W/m <sup>2</sup>  |  |                                       |
|      | Response Time (63%): <0.7s  |  |                                       |
|      | Response Time (95%): <2s  |  |                                       |
|      | Non Stability: < 0.5%   |  |                                       |
|      | Non Linearity < 0.2%  |  |                                       |
|      | Detector Type: Thermopile   |  |                                       |
|      | Field of view: At least 180°  |  |                                       |
|      | Output cable length: At least 5m  |  |                                       |
|      | IP Protection: At least IP67 according to IEC 60529   |  |                                       |
|      | Operating Temperature: Minimum range of -20°C to +50°C  |  |                                       |
|      | Fitting Arrangement: The mounting structure for Pyranometer should be parallel to the earth surface provided with stainless steel nut and bolts at the highest point of PV Module     |  |                                       |
|      | Mean Time Between Failures (MTBF): At least 10 Years  |  |                                       |
|      | Temperature Sensor: Thermister of 10kΩ with thermal tape to adhere in the back of module  |  |                                       |
|      | Compensated Calibrated Cell with internal temperature compensation: <ul style="list-style-type: none"> <li>At least 2 numbers with minimum dimension of 266mm x266mm x35mm</li> </ul> |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | <ul style="list-style-type: none"> <li>Voltage Radiation Relation: 65 mVdc per output = 1000W/m<sup>2</sup> ±2,1%</li> <li>Measurement Error: ±0.1%</li> </ul>   |  |                                       |
|      | International Certification:<br>Comply with ISO 9060:2018,<br>IEC 61724  |  |                                       |
| 5    | Pyrheliometer  |  |                                       |
|      | Direct Normal Irradiance (DNI) measuring sensor (Pyrheliometer) which can be used in combination with any pyranometer to measure the DNI and Global Horizontal Irradiance (GHI) should be provided. <ul style="list-style-type: none"> <li>Range: 0-2000 W/m<sup>2</sup></li> <li>Drift: upto +/- 2% /year</li> <li>Accuracy: +/- 5% of Full scale</li> <li>Operating Temperature: -40 -65C</li> <li>Spectral response: 300-3000 nm</li> </ul> |  |                                       |
| 6    | Wind Speed Sensor  |  |                                       |
|      | <ul style="list-style-type: none"> <li>Range: 0 to 125 mph (0 to 57 m/s) or more</li> <li>Accuracy: ±2mph (3km/h, 1m/s) or ±5 %, whichever is greater</li> <li>Resolution: 1mph (1Knot, 0.1m/s, 1km/hr)Time Constant: no more than 2 seconds</li> </ul>  |  |                                       |
| 7    | Wind Direction Sensor  |  |                                       |
|      | <ul style="list-style-type: none"> <li>Operating Range: 360° mechanical; 355° electrical (5° open) or</li> <li>Range: 0°to 360°or 16 compass points</li> <li>Accuracy: +/- 7°</li> <li>Resolution: 1°, 22.5° between compass points.</li> </ul>  |  |                                       |
| 8    | Air Temperature Sensor   |  |                                       |
|      | <ul style="list-style-type: none"> <li>Resolution: +/- 0.04 (min) to max +/- 0.01</li> <li>Typical accuracy: +/- 0.3 (maximal is +/- 1.5) Repeatability is (+/-) 0.1 celsius</li> </ul>  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | <ul style="list-style-type: none"> <li>Operating Range: -10 to +60 Celsius.</li> <li>Long term drift: &lt; 0.04 Celsius/year.</li> </ul>   |  |                                       |
| 9    | Wet-Bulb Temperature Meter   |  |                                       |
|      | Stevenson screen including stands and other related materials and items to house dry bulb/air temperature thermometer/ Wet bulb temperature thermometer <ul style="list-style-type: none"> <li>Measurement ranges: 0 to 100% r.h., -30 to 100°C</li> <li>Resolution: 0.01% r.h. 0.01°C</li> <li>Accuracy: <math>\pm 2.0\%</math> r.h. at 25°C, <math>\pm 0.5^\circ\text{C}</math> at 25°C</li> </ul> |  |                                       |
| 10   | Relative Humidity Sensor   |  |                                       |
|      | <ul style="list-style-type: none"> <li>Range: 0 to 100%, non-condensing</li> <li>Accuracy: + 1% RH from 3 to 95%;</li> <li>Response time: less than 20s</li> </ul>   |  |                                       |
| 11   | Rain Precipitation Sensor  |  |                                       |
|      | <ul style="list-style-type: none"> <li>Temperature: 0 to + 50° C</li> <li>Diameter of aperture: 225mm</li> <li>Orifice: 400cm<sup>2</sup></li> <li>Resolution/Sensitivity: 0.2mm</li> <li>Rainfall capacity: Unlimited</li> <li>Capacity per Minute: Max. 30 tips (3 resp. 6mm)</li> <li>Accuracy: <math>\pm 1\%</math> (at 25 mm/hr.)</li> </ul>  |  |                                       |
| 12   | Pressure Sensor  |  |                                       |
|      | <ul style="list-style-type: none"> <li>Range is 300-1100 hPa,</li> <li>Resolution is 0.06 hPa to 0.02hPa.</li> <li>Operating range is -40C to 85C. Best results in 0C to 65C range.</li> <li>Long term stability is <math>\pm 1</math> hPa/year.</li> </ul>  |  |                                       |
| 13   | Soil Temperature Sensors and Soil Moisture   |  |                                       |
|      | Soil Temperature Sensor: <ul style="list-style-type: none"> <li>Measuring surface-soil temperatures WMO standard</li> <li>The sensor levels should correspond to the WMO</li> </ul>  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | instructions (WMO No. 8), with additional sensors at ground level and 5 cm above it <ul style="list-style-type: none"> <li>• Measurement range: -20 to +60 °C</li> <li>• Resolution: 0.1 °C</li> <li>• Accuracy: <math>\pm 0.1</math></li> </ul>   |  |                                       |
|      | Soil Moisture: <ul style="list-style-type: none"> <li>• Soil water content measurements between 10cm and 1m</li> <li>• Precision: <math>&lt; \pm 0.2\%</math> volume</li> <li>• Operating range: - 10° to 60°C</li> </ul>  |  |                                       |
| 14   | Evaporation Pan Sensor   |  |                                       |
|      | <ul style="list-style-type: none"> <li>• Range: 0 to 250 mm water gauge</li> <li>• Accuracy: 1mm of water dept</li> </ul>  |  |                                       |
| 15   | Mounting Structure   |  |                                       |
|      | <ul style="list-style-type: none"> <li>• Single Pole - 3.5-meter installation (SS Pole)</li> <li>• Concrete work to be done to provide more stability to the system</li> <li>• All the related accessories to be provided</li> </ul>   |  |                                       |
| 16   | Data Logger  |  |                                       |
|      | <ul style="list-style-type: none"> <li>• A multipurpose Meteorological Data Measurement Logger to receive data from at least 12 meteorological sensors. Capacity to store recorded values for a minimum of one year on disconnection of the network</li> <li>• Data synchronization in case of non-availability of network, data is stored locally which is pushed further when network is available</li> <li>• The software must support WMO compliant measuring methods, especially for wind gust monitoring (4 samples per second) and wind vector monitoring</li> <li>• Local RTC - Local I2C based RTC with low drift with respect to time.</li> <li>• PC software for SD card - PC software for reading data from SD card of at least 8GB</li> </ul> |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | <ul style="list-style-type: none"> <li>The stored data must be able to be retrieved by direct connection to the logger with laptop computer. Data is also transmitted to a central data receiving system via a GPRS modem which, ideally, should be housed within the logger enclosure/case</li> <li>8 Bit micro-controller with low power consumption and functionality to go in deep sleep mode to consume less power. Controller should have 10-bit ADC resolution, 8 Analog inputs I2C port, UART port, Ability to change data push interval</li> <li>Data protocol - Bencode based data protocol should be used to transfer data from weather station to Webserver in real time.</li> <li>Power: It should run either from 12V DC power supply or Solar power</li> <li>Battery Back-up: 4.4 Ah Lithium Polymer battery which should at least give back-up of 7 days without recharge</li> <li>Enclosure: At least IP 65 based weatherproof enclosure with MX connectors to connect the sensor so that the logger is totally insulated from the surrounding environmental conditions</li> <li>Compatibility: Window 10 or Linux or better</li> </ul> |  |                                       |
| 17   | Web Dashboard and Web Server   |  |                                       |
|      | <ul style="list-style-type: none"> <li>Webserver to receive, store and analyse data.</li> <li>Weekly and Monthly reports on the mail.</li> <li>SMS / Email based alert mechanism.</li> <li>REST API for further integration or development of institute own dashboard. Visualization of data on last 6 hour, last 24-hour, last week</li> </ul>  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | <ul style="list-style-type: none"> <li>Functionality to download data between a specified date interval.</li> <li>Public access - If requested, same data should be made available to public also</li> </ul> |  |                                       |
| 18   | Power Supply from Solar:<br>PV module capacity: At least 75Wp<br>Charge controller: At least 6A<br>Battery: At least 40Ah  |  |                                       |
| 19   | Communication Interface: RS485 or Ethernet or USB-C  |  |                                       |
| 20   | Monitoring: Remote data sensing  |  |                                       |
| 21   | The Bidder must submit the technical datasheet of all the measurement system of Weather Station  |  |                                       |

### 1.3 Grid Connected Inverter

The total required Grid connected inverter capacity must be at least 440kVA. The Grid connected inverter shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model  |  |                                       |
| 2    | Manufacturer's experience in manufacturing inverters:<br>At least 10 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or ISO 14001:2015,<br>OHSAS 18001:2007 or<br>OHSAS 18001:2017/ISO 45001:2018<br>Certificates |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from inverter manufacturer in their letter head signed and stamped  |  |                                       |
| 5    | Inverter type: Three Phase Grid Connected and Multi-MPPT String  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 6    | DC to AC Ratio: At least 1.15  |  |                                       |
| 7    | Maximum No. of PV Strings per MPPT: 2<br>No. of Independent MPPT Inputs: At least 8  |  |                                       |
| 8    | Output AC Power Capacity: Total Cumulative Capacity of at least 440kVA@45°C<br>(Individual inverter capacity shall be at least 110kVA@45°C)<br>No. of Inverters: At least 4  |  |                                       |
| 9    | AC output Voltage:<br>Three Phase 400±10% Vac (L-L),<br>Single Phase 230 ±10% Vac (L-N)  |  |                                       |
| 10   | Isolation: Transformerless   |  |                                       |
| 11   | Output Frequency: 50 Hz ± 2.5%   |  |                                       |
| 12   | Output Wave form: Pure Sine Wave   |  |                                       |
| 13   | Peak efficiency: At least 97%  |  |                                       |
| 14   | Euro efficiency: At least 97%  |  |                                       |
| 15   | Inverter efficiency: The efficiency when operating loads at power levels within 40% to 90% of the rated load must be greater than 90%. The bidder must submit efficiency curve of the inverter to justify operational efficiency |  |                                       |
| 16   | Total Harmonic Distortion (THD): < 3%  |  |                                       |
| 17   | Power factor at nominal power: >0.99<br>Power factor range: 0.85 lag to 0.95 lead  |  |                                       |
| 18   | Degree of Protection: At least IP66 according to IEC 60529   |  |                                       |
| 19   | Protection: DC reverse polarity, grid monitoring, PV string current monitoring, overvoltage, AC short circuit  |  |                                       |
| 20   | Grid support: LVRT, HVRT, Active and reactive power control  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 21   | Operating Temperature: Minimum range of -20°C to +50°C   |  |                                       |
| 22   | Communication Interface: Modbus or RS232 or RS485 or Ethernet pack embedded, must communicate with other equipment & monitoring system and must have data logging features   |  |                                       |
| 23   | <p>International Certifications: IEC 61727:2004, IEC 62116:2014, IEC 62109-1:2010 &amp; IEC 62109-2:2011, IEC 61683:1999, IEC 60068 and IEC 61000</p> <p>The test certificates must be provided. The Test Certificates from IEC accredited independent laboratory must be provided. The Inverter must be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of Inverter Testing.</p> |  |                                       |
| 24   | The Datasheet and Name Plate Information of Photovoltaic Inverter must comply as per IEC 62894.  |  |                                       |
| 25   | The manufacturer must have accreditation for conformity to ISO/IEC 17025 Standard. The document/certificate must be provided.  |  |                                       |
| 26   | All Grid connected inverters offered for the project must be of same type, same model, same power rating and from the same manufacturer.   |  |                                       |
| 27   | The Bidder must submit the technical datasheet of Grid Connected Inverter.   |  |                                       |

#### 1.4 Support Structure for PV Modules

The Support Structure shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name  |  |                                       |
| 2    | Manufacturer's experience in manufacturing support structure:<br>At least 5 years  |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates  |  |                                       |
| 4    | Tilt angle and orientation: Optimum PV production angle at given latitude/longitude of the site, oriented towards south  |  |                                       |
| 5    | The support structure design and foundation or fixation mounting arrangements shall consider all static and dynamic loads suitable for site. The support structure design and foundation or fixation mounting arrangements must withstand wind speed up to 170 km/hr. The wind load + snow analysis must be provided.  |  |                                       |
| 6    | The PV module structure must be made of MS hot dip galvanized suitable sections of rectangular tubes, angles and channels. The minimum standards to be followed are:<br>Vertical leg (Main leg): Minimum 80mmx40mmx2mm<br>Rectangular Hollow Section<br><br>Rafter: Minimum 80mmx40mmx2mm<br>Rectangular Hollow Section<br><br>Purlin: Minimum 80mmx40mmx2mm<br>Rectangular Hollow Section |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | <p>Column bracing or supporting bracing: Minimum 40mmx40mmx5mm angle</p> <p>Base plate: Minimum 200mmx200mmx6mm</p> <p>The horizontal spacing between 2 vertical legs must be between 1.5-2 meters as per load conditions.</p> <p>The PV array must be designed with cross section with maximum 2 numbers for vertical placement and maximum 4 numbers for horizontal placement. There must be minimum of 25mm uniform spacing between the modules.</p> <p>The minimum thickness of galvanization must be at least 90 microns throughout the surface. The test report for random sampling of structure members must be provided from authorized test laboratory.</p> |  |                                       |
| 7    | The support structure and its accessories shall be able to resist at least 20 years of outdoor exposure without suffering damage or corrosion.   |  |                                       |
| 8    | The support structure shall be installed in such a way that PV array shading is minimized as much as possible considering site condition   |  |                                       |
| 9    | The minimum clearance between ground level and bottom edge of the PV modules/arrays must be at least 50cm.   |  |                                       |
| 10   | Stainless Steel (SS 304) nuts, bolts, washers must be used for fixing modules with the structure.  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | Stainless Steel (SS 304) or Galvanized nuts, bolts, washers, mounting clamps should be used for fixing structure and compatible with materials which it is being fixed. In case of welding structure, the galvanization must be done after the fabrication work. |  |                                       |
| 11   | The foundation of PV structure shall be minimum 0.8 meter deep with 0.3(L) x 0.3(B) size with 0.3m thick stone soling with sand filling and 0.3(L) x 0.3(B) x 0.8(H) pillar in 1:2:4 PCC with 0.3m pillar above ground.  |  |                                       |

### 1.5 Junction Box

The junction boxes are to be provided in the PV array for the termination of PV string connecting cables. The Junction box shall comply with following standards and technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in manufacturing junction boxes:<br>At least 5 years  |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates   |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from junction box manufacturer in their letter head signed and stamped   |  |                                       |
| 5    | The Junction box must be rated for exterior installation suitable for the site conditions, shall be UV and weather resistant.<br>Degree of Protection: At least IP65 according to IEC 60529 |  |                                       |

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 6           | The junction box installation must be protected from direct rain, sun and dust. The junction box must be suitable for mounting on the module support structures.  |   |  |
| 7           | If the fuses are not provided at input side of Inverter (inside the inverter), each junction box must include the PV string fuses as recommended by PV module manufacturer. The PV string fuse must be provided in both positive & negative sides in the box and must have IEC 60947-3. |   |  |
| 8           | Fuses must be cylindrical type mounted on appropriately sized non exposed type DC fuse block or DC fuse holders. The fuse holders/block may be DIN rail adapted.<br>Degree of Protection: At least IP20 according to IEC 60529  |   |  |
| 9           | The Fuse must be designed for at least nominal voltage of DC 1000V.   |   |  |
| 10          | The junction box must be provided with copper bus bars with suitable termination blocks.  |   |  |
| 11          | A junction box must be provided for each PV String.   |   |  |
| 12          | The junction box must be provided with IEC 62208 hinged door with EPDM rubber gasket to prevent water entry.  |   |  |
| 13          | All cables must be connected properly and cable entering/outings into/from the box must be sealed properly (use of cable glands, copper cables lugs, cable ties) so that dust and insects, mice cannot enter the box.   |   |  |
| 14          | The PV Connectors to be used connecting to the MPPT input of the Inverter must be compatible with the   |   |  |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | original PV module connector. Only the connector type supplied by the module manufacturer or approved by the module manufacturer must be used and must comply with IEC 62852.   |  |                                       |
| 15   | The PV Connectors must be provided with degree of protection of at least IP68 according to IEC 60529.   |  |                                       |
| 16   | The cable glands must be provided with degree of protection of at least IP66 according to IEC 60529.  |  |                                       |
| 17   | <p>International Certification:<br/>IEC 61439-1:2011 or IEC 61439-1:2020,<br/>IEC 61439-2:2011 or IEC 61439-2:2020,<br/>IEC 60947-3</p> <p>The test certificates must be provided. The Test Certificates from IEC accredited independent laboratory must be provided. All the components must be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of Testing.</p> |  |                                       |
| 18   | The Bidder must submit the technical datasheet of Junction Box and PV String Fuse.  |  |                                       |

### 1.6 Grid Connected AC Combiner Box

The Grid connected AC combiner box shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model  |  |                                       |
| 2    | Manufacturer's experience in manufacturing combiner boxes:<br>At least 5 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates  |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from combiner box manufacturer in their letter head signed and stamped  |  |                                       |
| 5    | The Grid Connected AC combiner box must be rated for exterior installation suitable for the site conditions, shall be UV and weather resistant.<br>Degree of Protection: At least IP65 according to IEC 60529          |  |                                       |
| 6    | The combiner box must be provided with copper bus bars with suitable termination blocks.   |  |                                       |
| 7    | The combiner box must be provided with IEC 62208 hinged door with EPDM rubber gasket to prevent water entry  |  |                                       |
| 8    | The combiner box must have<br>AC 4P MCCB: At least 200A connecting the output of Grid Connected Inverter<br>AC 4P MCCB: At least 800A connecting the input of AC Distribution Board<br>and MCCB must have IEC 60947-2. |  |                                       |
| 9    | The MCCB must be used to isolate each output of Inverter and the output of AC combiner box.<br>Degree of Protection: At least IP20 according to IEC 60529  |  |                                       |
| 10   | The combiner box must have appropriately sized AC surge  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | protection device for each inverter output. The SPD must have IEC 61643-11:2011 and grounded adequately.   |  |                                       |
| 11   | The SPD must be Type 1+2, 20kA nominal discharge and 40 kA maximum discharge current.<br>Degree of Protection: At least IP20 according to IEC 60529  |  |                                       |
| 12   | The MCCB and SPD must be designed for at least nominal voltage of AC 400V.   |  |                                       |
| 13   | All cables must be connected properly and cable entering/outings into/from the box must be sealed properly (use of cable glands, copper cables lugs, cable ties) so that dust and insects, mice cannot enter the box   |  |                                       |
| 14   | The cable glands must be provided with degree of protection of at least IP66 according to IEC 60529  |  |                                       |
| 15   | International Certifications:<br>IEC 60947-2 for AC MCCB,<br>IEC 61643-11:2011 for AC SPD<br>IEC 61439-1:2011 or IEC 61439-1:2020,<br>IEC 61439-2:2011 or IEC 61439-2:2020 for AC Combiner Box<br>The test certificates must be provided. The Test Certificates from IEC accredited independent laboratory must be provided. All the components must be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of Testing. |  |                                       |

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 16          | The Bidder must submit the technical datasheet of Grid connected AC combiner box, AC MCCB and AC SPD. |   |  |

## 1.7 AC Distribution Board

The AC Distribution Board shall comply with following standards and technical specifications.

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 1           | Manufacturer Name/Brand/Model   |   |  |
| 2           | Manufacturer's experience in manufacturing distribution board:<br>At least 5 years  |   |  |
| 3           | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates   |   |  |
| 4           | Warranty: Manufacturing warranty of at least 5 years from distribution board manufacturer in their letter head signed and stamped   |   |  |
| 5           | The AC Distribution Board must be rated for installation suitable inside the control room<br>Degree of protection: At least IP54 according to IEC 60529                                 |   |  |
| 6           | The distribution board must be provided with copper bus bars with suitable termination blocks.  |   |  |
| 7           | The distribution board must be provided with hinged door with EPDM rubber gasket.   |   |  |
| 8           | The distribution board must have<br>AC 4P MCCB: At least 800A connecting the output of Grid Connected AC Combiner Box<br>AC 4P MCCB: At least 1000A connecting the input of Transformer |   |  |

| <b>S.N.</b> | <b>Specifications Required</b>   | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|--|---|--|
|             | System and MCCB must have IEC 60947-2  |   |  |
| 9           | The MCCB must have rotary handle operating mechanism, protection system and remote electronic tripping function.   |   |  |
| 10          | The MCCB must be used to isolate output of AC combiner box and input of Transformer System<br>Degree of Protection: At least IP20 according to IEC 60529   |   |  |
| 11          | The distribution board must have appropriately sized AC surge protection device. The SPD must have IEC 61643-11:2011 and grounded adequately.  |   |  |
| 12          | The SPD must be Type 1+2, 20kA nominal discharge and 40 kA maximum discharge current.<br>Degree of Protection: At least IP20 according to IEC 60529  |   |  |
| 13          | The MCCB and SPD must be designed for at least nominal voltage of AC 400V.   |   |  |
| 14          | All cables must be connected properly and cable entering/outings into/from the box must be sealed properly (use of cable glands, copper cables lugs, cable ties) so that dust and insects, mice cannot enter the box |   |  |
| 15          | The cable glands must be provided with degree of protection of at least IP66 according to IEC 60529  |   |  |
| 16          | International Certifications:<br>IEC 60947-2 for AC MCCB,<br>IEC 61643-11:2011 for AC SPD<br>IEC 61439-1:2011 or IEC 61439-1:2020,<br>IEC 61439-2:2011 or IEC 61439-2:2020 for AC Distribution Board                 |   |  |

| <b>S.N.</b> | <b>Specifications Required</b>   | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|--|---|--|
|             | The test certificates must be provided. The Test Certificates from IEC accredited independent laboratory must be provided. All the components must be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of Testing. |   |  |
| 17          | The Bidder must submit the technical datasheet of AC Distribution Board, AC MCCB and AC SPD.   |   |  |

### 1.8 Cables and Accessories

The cables and accessories shall comply with following standards and technical specifications.

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 1           | Manufacturer Name/Brand   |   |  |
| 2           | Manufacturer's experience in manufacturing cables: At least 5 years   |   |  |
| 3           | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates   |   |  |
| 4           | PV String Cable:  |   |  |
|             | The cables sizes shall be selected considering the power loss, current carrying capacity, voltage drop, and the period of short circuit to meet the anticipated currents. |   |  |
|             | The PV string cable must be copper multi-strand, PVC insulated and UV resistant. The string cable   |   |  |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | must be PV1-F type and must comply with<br>IEC 62930 or EN 50618,<br>IEC 60228,<br>IEC 60332-1 or EN 50575,<br>IEC 60754-1 or EN 50525  |  |                                       |
|      | The PV string cable must be specific for PV application with double insulation layers.  |  |                                       |
|      | The PV string cable must be 1100 V (minimum) grade, single/multi core.  |  |                                       |
| 5    | Cabling for DC Cables:  |  |                                       |
|      | The cables must be laid underground in trenches and through suitable size of flexible HDPE Pipe with minimum PN6 Class wherever required and necessary according to relevant IEC standards and best installation practice.  |  |                                       |
|      | The underground installation cables must be laid at depth not less than 0.8m below ground level. Prior to cable laying, the bottom of the trench shall be well compacted and bedded with fine sand of at least 75mm. Subsequently the second layer of fine sand of at least 75mm shall be spread over the cable and then covered by brick and compacted soil. |  |                                       |
| 6    | AC Cable from Grid Connected Inverter to Grid Connected AC Combiner Box & Grid Connected AC Combiner Box to AC Distribution Board   |  |                                       |
|      | The cables sizes shall be selected considering the power loss, current carrying capacity, voltage drop, maximum short circuit duty and the  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | period of short circuit to meet the anticipated currents.  |  |                                       |
|      | The cable from Grid connected inverter to Grid connected AC combiner box, must be 1100V (minimum) grade, multi core, copper XLPE insulated with extruded PVC inner sheath.   |  |                                       |
|      | The conductor shall be high conductivity annealed copper and shall be smooth, uniform in quality and free from scale and any defects.  |  |                                       |
|      | The maximum conductor temperature for PVC insulation shall not exceed 70°C during continuous operation at full rated current. The temperature after short circuit for 1 second shall not exceed 160°C with initial conductor temperature of 70°C.  |  |                                       |
|      | The cable from Grid connected AC combiner box to AC distribution board must be 1100V (minimum) grade, multi core, aluminium XLPE insulated with extruded PVC inner sheath.   |  |                                       |
|      | The maximum conductor temperature for XLPE insulation shall not exceed 90°C during continuous operation at full rated current. The temperature after short circuit for 1 second shall not exceed 250°C with initial conductor temperature of 90°C. |  |                                       |
|      | The cables shall be armoured with mild steel wires or strips as required for underground and in trench installations.  |  |                                       |
|      | The cables must comply with IEC 60502-1 and IEC 60228.   |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 7    | Cabling for AC Cables:  |  |                                       |
|      | The cables must be laid underground in trenches and through pipe sleeves wherever required and necessary according to relevant IEC standards and best installation practice.  |  |                                       |
|      | The underground installation cables must be laid at depth not less than 0.8m below ground level. Prior to cable laying, the bottom of the trench shall be well compacted and bedded with fine sand of at least 75mm. Subsequently the second layer of fine sand of at least 75mm shall be spread over the cable and then covered by brick and compacted soil.   |  |                                       |
|      | In case of road crossing, all cables must be installed in conduit, suitable flexible HDPE Pipe with minimum PN6 Class and 1:2:4 RCC concrete.   |  |                                       |
|      | All cable terminations must be mechanically and electrically sound and shall comply with relevant standards.  |  |                                       |
|      | All the excavation and back fill required for the installation of the cables must be carried out. The contractor must restore all surfaces, roadways, side walls, curbs, walls, landscaping or other works cut for excavation to their original condition. Underground cables and cable joints shall be marked on the surface by markers generally manufactured and tested to the requirements of relevant standards. |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 8    | The allowable voltage drop from PV Module or PV Array to Grid connected inverter must not exceed 3% and from Grid connected inverter to AC distribution board must not exceed 5%.  |  |                                       |
| 9    | The cross section of DC and AC cable must be as follows.<br>PV String Cable: At least 4mm <sup>2</sup><br>AC Cable from Grid Connected Inverter to Grid Connected AC Combiner Box: At least 3.5C x 95mm <sup>2</sup><br>AC Cable from Grid Connected AC Combiner Box to AC Distribution Board: 2 numbers with each of at least 3.5C x 500mm <sup>2</sup>                                 |  |                                       |
| 10   | International Certification: IEC 62930 or EN 50618<br><br>The test certificate must be provided. The Test Certificate from IEC accredited independent laboratory must be provided. The cables must be certified by Certification Body Testing Laboratory (CBTL) or National Certification Body (NCB) enlisted in the IECEE website. The enlisted CBTL or NCB must have Scope of Testing. |  |                                       |
| 11   | The Bidder must submit the technical datasheet of DC and AC Cables, HDPE Pipe.   |  |                                       |

## 1.9 Earthing System

The earthing system shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model  |  |                                       |
| 2    | Manufacturer's experience in manufacturing Earthing System:<br>At least 10 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates  |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from earthing system manufacturer in their letter head signed and stamped   |  |                                       |
| 5    | All the metallic parts of the PV modules frame must be interconnected by insulated multi-stranded copper earth wire of minimum cross section of 16mm <sup>2</sup> and tinned copper compression lug  |  |                                       |
| 6    | The PV array connected to each Grid connected inverter, must have separate equipotential bonding system.   |  |                                       |
| 7    | The PV modules frame and array structure, SPDs, junction boxes, Grid connected AC combiner box must be connected to equipotential bonding system by insulated multi-stranded copper earth wire of minimum cross section of 16mm <sup>2</sup> . |  |                                       |
| 8    | The equipotential bonding system must be connected to the earth termination system by insulated multi-stranded copper earth wire of minimum cross section of 25mm <sup>2</sup> .<br>The maximum allowable earth resistance is 5 Ohms.          |  |                                       |
| 9    | Each Grid connected inverter must be connected to separate earth termination system by insulated multi-stranded copper earth wire of minimum cross section of 25mm <sup>2</sup> .  |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | The maximum allowable earth resistance is 5 Ohms.   |  |                                       |
| 10   | The AC distribution board must be connected to separate earth termination system by insulated multi-stranded copper earth wire of minimum cross section of 25mm <sup>2</sup> .<br>The maximum allowable earth resistance is 5 Ohms.   |  |                                       |
| 11   | The underground earth cable must be of bare copper earth conductor with minimum cross section of 25mm <sup>2</sup> .  |  |                                       |
| 12   | The cables must be laid underground in trenches and through suitable size of flexible HDPE Pipe with minimum PN6 Class wherever required and necessary according to relevant IEC standards and best installation practice.  |  |                                       |
| 13   | The underground installation cables must be laid at depth not less than 0.8m below ground level. Prior to cable laying, the bottom of the trench shall be well compacted and bedded with fine sand of at least 75mm. Subsequently the second layer of fine sand of at least 75mm shall be spread over the cable and then covered by brick and compacted soil. |  |                                       |
| 14   | Earth Termination System:   |  |                                       |
|      | The earth electrode must be of Pipe-in-Pipe technology and the inner space must be filled with highly conductive and corrosion resistant compound.  |  |                                       |
|      | The length of earth electrode must be at least 2.5 meters.  |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | The earth electrode must be made of copper.   |  |                                       |
|      | The earth electrode must have outer diameter of at least 50mm and inner diameter of at least 25mm.  |  |                                       |
|      | A hole of minimum 100mm diameter or as per manufacturer's recommendation must be dug for the length of electrode.   |  |                                       |
|      | The earth wire must be connected to the individual earth electrode with the use of tinned copper compression lug.   |  |                                       |
|      | The certified low resistivity earth enhancement material must be used to fill the hole with the electrode.  |  |                                       |
|      | The earth enhancement material must be at least 50kg for each earthing electrode.   |  |                                       |
|      | The maximum allowable earth resistance is 5 Ohms.   |  |                                       |
|      | The earth inspection pit of each earthing electrode must be made of solid concrete with the minimum dimension of 300m x 300mm x300mm. The cover must be marked with the word "Earth". |  |                                       |
|      | The earth termination system must comply with IEC 62305.  |  |                                       |
| 15   | Earthing 1: PV modules frame and array structure, junction boxes, Grid connected AC combiner box<br>Earthing 2,3,4&5: Grid connected inverter<br>Earthing 6: AC distribution board    |  |                                       |
| 16   | Earthing 1: At least 2 nos of earth electrode<br>Earthing 2,3,4&5: At least 1 no of earth electrode for each Grid connected inverter  |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | Earthing 6: At least 1 no of earth electrode for AC distribution board           |  |                                       |
| 17   | Separation between earthing system: At least height of earthing electrode        |  |                                       |
| 18   | The Bidder must submit the technical datasheet of Earthing System and HDPE Pipe. |  |                                       |

### 1.10 Lightning Protection System

The lightning protection system shall comply with following standards and technical specifications.

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model:   |  |                                       |
| 2    | Manufacturer's experience in manufacturing Lightning Protection System: At least 10 years  |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates                        |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from lightning protection system manufacturer in their letter head signed and stamped |  |                                       |
| 5    | The lightning protection system must be designed according to the IEC 62305.   |  |                                       |
| 6    | Air Termination System   |  |                                       |
|      | The air terminal rod must be at a minimum height of 2 meter above the highest point of the PV array to be protected.                       |  |                                       |
|      | The length of air terminal rod must be at least 1 meter.   |  |                                       |
|      | The air terminal rod must be made of solid copper.   |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | The diameter of air terminal rod must be at least 15mm.   |  |                                       |
|      | The air terminal rod must have at least 4 spikes at minimum angle of 25° with the horizontal surface and arrester base.   |  |                                       |
|      | The air terminal rod must be rated to withstand a discharge current capacity of 200kA.  |  |                                       |
|      | The air terminal rod must be installed on a separate concrete base as a free standing air terminal mast. The mast must be made of solid GI pipe of at least 75mm diameter and 3mm thickness.  |  |                                       |
|      | The quantity of air terminal rods to be used must be at least 4 nos.  |  |                                       |
|      | The separation distance between the air terminal rod and the closest metallic part of PV array must be as per IEC 62305.  |  |                                       |
|      | The separation distance between the air terminal rods must be at least the height of earthing electrode.  |  |                                       |
|      | Each terminal rod must have separate earth termination system.  |  |                                       |
|      | The air termination system must comply with IEC 62305.  |  |                                       |
| 7    | Down Conductor:   |  |                                       |
|      | The size of down conductor must be at least 25mm width x 6mm thickness copper strip, connecting the lower extremity of air terminal rod to the earthing electrode of earth termination system |  |                                       |
|      | The cable must be buried at minimum 0.5 height at ground level.   |  |                                       |
|      | The copper strip must be connected to the earth electrode with the use of copper compression lug.   |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | The earth termination system must comply with IEC 62305.   |  |                                       |
| 8    | Earth Termination System:  |  |                                       |
|      | The earth electrode must be of Pipe-in-Pipe technology and the inner space must be filled with highly conductive and corrosion resistant compound.                                     |  |                                       |
|      | The length of earth electrode must be at least 2.5 meters.   |  |                                       |
|      | The earth electrode must be made of copper.  |  |                                       |
|      | The earth electrode must have outer diameter of at least 50mm and inner diameter of at least 25mm.   |  |                                       |
|      | A hole of minimum 100mm diameter or as per manufacturer's recommendation must be dug for the length of electrode.  |  |                                       |
|      | The certified low resistivity earth enhancement material must be used to fill the hole with the electrode.   |  |                                       |
|      | The earth enhancement material must be at least 50kg for each earthing electrode.  |  |                                       |
|      | The maximum allowable earth resistance is 5 Ohms.  |  |                                       |
|      | The earth inspection pit of each earthing electrode must be made of solid concrete with the minimum dimension of 300mm x 300mm x300mm. The cover must be marked with the word "Earth". |  |                                       |
|      | The earth termination system must comply with IEC 62305.   |  |                                       |
| 9    | The Bidder must submit the technical datasheet of Air Termination System, Down Conductor and Earth Termination System.   |  |                                       |

### 1.11 Monitoring System and Data Acquisition System

The Monitoring System and data acquisition system shall comply with following standards and technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in manufacturing monitoring system:<br>At least 5 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates   |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from monitoring system manufacturer in their letter head signed and stamped  |  |                                       |
| 5    | RS485 or Modbus communication port for receiving data from PV strings, grid connected inverters etc   |  |                                       |
| 6    | RS232 or LAN port or Modbus for local monitoring or network monitoring  |  |                                       |
| 7    | Internet connection via GSM modem, CDMA, GPRS, 3G, 4G, ADSL, VSAT   |  |                                       |
| 8    | <p>The system must have remote monitoring software with the latest software/hardware configuration and service connectivity for online/real time data monitoring. The following parameters shall be accessible via the operating interface display in real time.</p> <ul style="list-style-type: none"> <li>• Array DC Voltage, Current &amp; Power</li> <li>• Inverter AC Output Voltage and Current (all 3 phases and lines)</li> <li>• AC Power (Active, Reactive and Apparent)</li> <li>• Power Factor</li> </ul> |  |                                       |

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
|             | <ul style="list-style-type: none"> <li>• Frequency</li> <li>• AC Energy (all 3 phases and cumulative)</li> </ul>  |   |  |
| 10          | The system must have plant monitoring station with necessary software/app compatible with the inverter.   |   |  |
| 11          | <p>The plant monitoring station must be provided as follows.</p> <p>Processor: At least Intel Core 10<sup>th</sup> Generation i7</p> <p>Memory: At least 16GB</p> <p>Hard Drive: At least 1TB SSD</p> <p>Wireless LAN: Dual band</p> <p>LED Monitor: At least 32" FHD</p> |   |  |
| 12          | The communication medium from PV Plant location to Control Room must be of Optical Fiber Cable with fiber switch, splice box and all necessary accessories for complete system operation. The fiber cable must be of at least 4 Core.                                     |   |  |
| 13          | The fiber cables must be laid underground in trenches and through pipe sleeves and suitable size of flexible HDPE Pipe with minimum PN6 Class according to relevant IEC standards and best installation practice.   |   |  |
| 14          | The bidder must submit the technical datasheet of Monitoring System, Data Acquisition System, Fiber Optics System and HDPE Pipe.  |   |  |

## 1.12 Containerized System (Control Room)

The containerized system shall comply with following technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in manufacturing containerized system: At least 5 years   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates   |  |                                       |
| 4    | Warranty: Manufacturing warranty of at least 5 years from containerized system manufacturer in their letter head signed and stamped   |  |                                       |
| 5    | The Containerized System must be rated for exterior installation suitable for the site conditions, shall be UV and weather resistant.<br>Degree of Protection: At least IP65 according to IEC 60529 |  |                                       |
| 6    | External Dimension: Minimum 6.09m (L) x 2.43m (W) x 2.59m (H)<br>Internal Dimension: Minimum 5.89m (L) x 2.35m (W) x 2.38m (H)  |  |                                       |
| 7    | The container must be provided with double door design on both ends   |  |                                       |
| 8    | The container must have a separate compartment for LV switchgears and separate for monitoring system & data acquisition system.   |  |                                       |
| 9    | The container must be made of corrugated steel and must comply as per Standard Shipping Container.  |  |                                       |
| 10   | The floor of the container must bear the floor loading of the equipment.  |  |                                       |

| <b>S.N.</b> | <b>Specifications Required</b>  | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 11          | The container must have ventilation louvres to maintain the inside temperature.   |   |  |
| 12          | The container must provide mounting board for AC Distribution Board, Monitoring System, Control System and all other accessories. |   |  |
| 13          | The container must be protected by 2-pack paint system i.e. single coat of primer & top 2 coat (Standard color: RAL 9010)         |   |  |
| 14          | The Containerized System must comply with ISO/TC 104.   |   |  |
| 15          | The Bidder must submit the technical datasheet of Containerized System.   |   |  |

### 1.13 Transformer

The transformer shall comply with following standards and technical specifications.

| <b>S.N.</b> | <b>Specifications Required</b>   | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|--|---|--|
| 1           | Manufacturer Name/Brand/Model  |   |  |
| 2           | Manufacturer's experience in manufacturing transformer:<br>At least 10 years   |   |  |
| 3           | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015 Certificate   |   |  |
| 4           | Warranty: Manufacturing warranty of at least 2 years from transformer manufacturer in their letter head signed and stamped |   |  |
| 5           | Transformer type: Three phase and outdoor oil filled   |   |  |
| 6           | Rated Capacity: At least 630kVA  |   |  |
| 7           | Rated Voltage:<br>Primary Voltage (LV): 400V<br>Secondary Voltage (HV): 11000V   |   |  |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 8    | Frequency: 50 Hz  |  |                                       |
| 9    | Type of Cooling: ONAN   |  |                                       |
| 10   | Impedance at 75°C: 0.05%  |  |                                       |
| 11   | Tolerance on Impedance: $\pm 10\%$  |  |                                       |
| 12   | Duty: Continuous  |  |                                       |
| 13   | Max. Temp. Rise over an ambient of 50°C<br>Oil (Temperature rise measurement by thermometer): 50°C<br>Winding Temperature rise measurement by resistance method): 55°C  |  |                                       |
| 14   | Windings:<br>System Apparent Short circuit level (kA): as per IEC 60076-1<br>Winding Connection:<br>LV: Star<br>HV: Delta   |  |                                       |
| 15   | Vector Group: Dyn11   |  |                                       |
| 16   | Insulation: Uniform   |  |                                       |
| 17   | Insulation Level:<br>LV: At least 2 kVrms<br>HV: At least 28 kVrms  |  |                                       |
| 18   | Basic Impulse Level:<br>HV: At least 75kVp  |  |                                       |
| 19   | Highest voltage (kV) for each winding: 12kV   |  |                                       |
| 20   | Method of earthing: Solidly earthed   |  |                                       |
| 21   | LV & Neutral Bushing:<br>Rated Voltage: At least 1.1kV<br>Rated current: At least 1000A<br>Wet & Dry Power frequency Withstand Voltage: At least 2kVrms<br>Min. Total Creepage Distance: 300mm<br>Mounting: Tank / Transformer Body |  |                                       |
| 22   | HV Bushing:<br>Rated Voltage: At least 12kV<br>Rated current: At least 100A<br>Basic Impulse Level: At least 75kVp  |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | Wet & Dry Power frequency Withstand Voltage: At least 28kVrms<br>Mounting: Tank / Transformer Body  |  |                                       |
| 23   | Terminal Details:<br>LV & Neutral: Cable Box<br>HV: Suitable for 11kV Cable or Over Head Conductor  |  |                                       |
| 24   | Min. Clearance in Air:<br>Ph-Ph (LV/HV): 25/280<br>Ph-Earth (HV/LV): 25/140   |  |                                       |
| 25   | Factory Test:   |  |                                       |
|      | All standard routine tests in accordance with latest issue of IEC: 60076 shall be carried out on each transformer.  |  |                                       |
|      | In addition to all type and routine tests, transformer shall also conform to following additional type tests as per IEC: 60076.<br>a) Measurement of zero sequence impedance<br>b) Short circuit test<br>c) Measurement of acoustic noise level. This shall conform to NEMA standard publication TR-1.<br>d) Measurement of capacitance and tan delta of transformer winding.<br>e) Test on oil samples as per IS 60296 |  |                                       |
|      | All auxiliary equipment shall be tested as per the relevant IS Test Certificates shall be submitted for bought out items.   |  |                                       |
|      | High voltage withstand test shall be performed on auxiliary equipment and wiring after complete assembly.   |  |                                       |
|      | Tank Tests:<br>i) Routine Tests: As per IEC: 60076 Part-1 including   |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | ii) Vacuum Tests: As per IEC: 60076 Part-1<br>iii) Pressure Test: As per IEC: 60076 Part-1  |  |                                       |
| 26   | The transformer must be supplied along with LA, DO Fuse, 11kV cable, cable termination kits and all accessories<br>Cross section of 11kV aluminium cable: At least 3Cx25mm <sup>2</sup> |  |                                       |
| 27   | The transformer must be ground mounted with mounting foundation and fencing.  |  |                                       |
| 29   | The HT Metering System (TOD Meter, CT, PT with all accessories) must be supplied as per NEA requirements.   |  |                                       |
| 30   | The Bidder must submit the technical datasheet of Transformer System, 11kV Cable.   |  |                                       |

### 1.14 Earthing System for Transformer

The earthing system shall comply with following standards and technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in manufacturing Earthing System:<br>At least 10 years                                    |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates |  |                                       |
| 4    | Earth Termination System:   |  |                                       |
|      | The earth electrode must be of Pipe-in-Pipe technology and the inner space must be filled with                      |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | highly conductive and corrosion resistant compound.  |  |                                       |
|      | The length of earth electrode must be at least 2.5 meters.   |  |                                       |
|      | The earth electrode must be made of copper.  |  |                                       |
|      | The earth electrode must have outer diameter of at least 50mm and inner diameter of at least 25mm.   |  |                                       |
|      | A hole of minimum 100mm diameter or as per manufacturer's recommendation must be dug for the length of electrode.  |  |                                       |
|      | The earth wire must be connected to the earth electrode with the use of tinned copper compression lug.   |  |                                       |
|      | The certified low resistivity earth enhancement material must be used to fill the hole with the electrode.   |  |                                       |
|      | The earth enhancement material must be at least 50kg for each earthing electrode.  |  |                                       |
|      | The maximum allowable earth resistance is 5 Ohms.  |  |                                       |
|      | The earth inspection pit of each earthing electrode must be made of solid concrete with the minimum dimension of 300mm x 300mm x300mm. The cover must be marked with the word "Earth". |  |                                       |
|      | The earth termination system must comply with IEC 62305.   |  |                                       |
| 5    | Earthing 7: Body<br>Earthing 8: Neutral<br>Earthing 9: LA  |  |                                       |
| 6    | Earthing 7: At least 1 no of earth electrode<br>Earthing 8: At least 1 no of earth electrode   |  |                                       |

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
|      | Earthing 9: At least 1 no of earth electrode                              |  |                                       |
| 7    | Separation between earthing system: At least height of earthing electrode |  |                                       |
| 8    | The Bidder must submit the technical datasheet of Earthing System.        |  |                                       |

### 1.15 Fire Fighting System

The fire fighting system shall comply with following technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | Manufacturer Name/Brand/Model   |  |                                       |
| 2    | Manufacturer's experience in manufacturing fire fighting system: At least 5 years                                   |  |                                       |
| 3    | The manufacturer shall have:<br>ISO 9001:2008 or ISO 9001:2015,<br>ISO 14001:2004 or<br>ISO 14001:2015 Certificates |  |                                       |
| 4    | The Fire Extinguishers with wall mounting bracket must be set-up in the PV array location and in the control room.  |  |                                       |
|      | Extinguisher: Portable CO <sub>2</sub> Fire Extinguisher  |  |                                       |
|      | Type: Stored pressure operated  |  |                                       |
|      | Capacity: At least 5 kg   |  |                                       |
|      | Propellant Gas: CO <sub>2</sub>   |  |                                       |
|      | Throw Length: At least 4 meters   |  |                                       |
|      | Suitability for electrical equipment: up to 1000V   |  |                                       |
|      | Color: Red (RAL 3000)   |  |                                       |
|      | Gross Weight: At least 14kg   |  |                                       |
|      | Standard: EN3   |  |                                       |
|      | PV array location: At least 2 numbers   |  |                                       |

| S.N. | Specifications Required  | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|--|--|---------------------------------------|
|      | Control Room: At least 2 numbers   |  |                                       |
| 5    | Minimum 2 sand buckets with stand must be provided in the control room.  |  |                                       |
| 6    | The installation of Fire Extinguishers should confirm to TAC regulations |  |                                       |

### 1.16 Fencing

The fencing shall comply with following technical specifications.

| S.N. | Specifications Required   | Specifications Offered with Compliance | Reference Document (Specify Document) |
|------|---|--|---------------------------------------|
| 1    | The chain link mesh size must be at least 2" x 2" of 10 guage   |  |                                       |
| 2    | The metal post must be at least 1.5 m high from ground level with MS angle iron of minimum size 50mm*50mm*5mm, with the maximum spacing of 2 m center to center |  |                                       |
| 3    | The iron angle post must be at least 0.5m below ground level in M15 concrete (1:2:4) with 0.2m*0.2m cover   |  |                                       |
| 4    | Fencing must include a MS iron lockable gate of 1.5m width and 2.5m height  |  |                                       |
| 5    | All angle iron must be MS hot dip galvanized. The minimum thickness of galvanization must be at least 90 microns throughout the surface.                        |  |                                       |
| 6    | There must be a free space of at least 3 m between the front of PV array and the fencing  |  |                                       |
| 7    | There must be a free space of at least 3 m between the side of PV array and the fencing   |  |                                       |

| <b>S.N.</b> | <b>Specifications Required</b>   | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|--|---|--|
| 8           | There must be a free space of at least 2 m on the back of PV array and the fencing |   |  |

### 1.17 Design and Drawings

The bidder shall prepare all the required design and drawings and include them in the technical proposal document.

| <b>S.N.</b> | <b>Specifications Required</b>   | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|--|---|--|
| 1           | The bidder shall follow the IEC 62548:2016 for design requirements   |   |  |
| 2           | The bidder shall follow IEC 62446-1:2016 for documentation, commissioning tests and inspection                   |   |  |
| 3           | The bidder shall follow IEC 62446-2:2016 for maintenance of PV systems   |   |  |
| 4           | 3D and 2D Layout of Grid Connected Solar PV System   |   |  |
| 5           | Single Line Diagram and Design of Solar PV System with all the Protection System and Cable Size (DC and AC both) |   |  |
| 6           | Design and drawing of Support Structure with Foundation  |   |  |
| 7           | Design and drawing of Wind Load +Snow Analysis   |   |  |
| 8           | Shading Analysis (Far and near shading)  |   |  |
| 9           | Design and drawing of Remote Monitoring System and Data Acquisition System                                       |   |  |
| 10          | Design and drawing of Junction Box   |   |  |

| <b>S.N.</b> | <b>Specifications Required</b>                            | <b>Specifications Offered with Compliance</b> | <b>Reference Document (Specify Document)</b> |
|-------------|---|---|--|
| 11          | Design and drawing of Grid Connected AC Combiner Box      |   |  |
| 12          | Design and drawing of AC Distribution Board               |   |  |
| 13          | Design and drawing of Earthing System                     |   |  |
| 14          | Design and drawing of Lightning Protection System         |   |  |
| 15          | Design and Drawing of Fencing with Foundation             |   |  |
| 16          | Design and drawing of Containerized System (Control Room) |   |  |
| 17          | Design and drawing of Transformer System                  |   |  |
| 18          | Design and drawing of Grid Interconnection System         |   |  |

### **1.18 System Operation and Maintenance**

The Contractor shall be fully responsible for any kind of operation and maintenance jobs, including the cleaning of PV modules. The contractor will depute one full time operator (Technical), equipment/tools, for operation of Grid Connected Solar PV System for five (5) years from the date of commissioning. A minimum of half yearly site visit must be done by the contractor's engineer to make sure the preventative maintenance and assure that all the system components are fully functional. The site visit report shall be submitted to MBUST within a week of each visit.

### **1.19 Project Information Board**

The project information board must be installed at the installation site after the completion of the project. The minimum information to be shown are:

- Name of the Project
- Location of the Project
- Date of Commissioning
- Name of the Employer
- Name of the Contractor
- Name of the Consultant

### 1.20 Spare Parts

The bidder must provide the following minimum spare parts upon the successful completion of testing and commissioning requirements.

| S.N. | Items   | Quantity        |
|------|---|-----------------|
| 1    | PV Module (0.5% of Total)                                   | At least 6 Nos  |
| 2    | PV Connector Pair (5% of Total)                             | At least 10 Nos |
| 3    | Inverter Fuse   | At least 10 Nos |
| 4    | Stainless Steel (SS 304) nuts, bolts, washers (1% of Total) | 1 Set           |
| 5    | Galvanized nuts, bolts, washers (0.5% of Total)             | 1 Set           |
| 6    | AC SPD  | At least 4 Nos  |
| 7    | Cable Lugs of various sizes (5% of Total)                   | 1 Set           |
| 8    | Cable Glands of various sizes (5% of Total)                 | 1 Set           |
| 9    | Insulating Gloves   | 5 Pairs         |
| 10   | Torque Wrench   | 1 No            |
| 11   | Spanner Set   | 1 Set           |
| 12   | Screw Driver Set  | 1 Set           |
| 13   | Allen Key Set   | 1 Set           |
| 14   | Crimping Tool   | 1 Set           |
| 15   | Clamp Meter   | 1 No            |
| 16   | Insulation Tester   | 1 No            |
| 17   | Earth Resistance Tester                                     | 1 No            |