

**MADAN BHANDARI
UNIVERSITY OF
SCIENCE AND TECHNOLOGY**


Chitlang, Thaha Municipality Ward 9, Bagmati Province

Clarification No. 1

Date: September 23, 2026 (Aswoj 07, 2083)

This is to notify all concerned that MBUST, Chitlang, Thaha Municipality has made the following clarifications on the queries of the bidders to the Bidding Documents for the Procurement of Supply, Delivery, Installation, Testing and Commissioning of Generator with ATS Panel published on September 03, 2026, Thursday (Bhadra 18, 2083) in the "Gorkhapatra" Daily Newspaper.

S. N	Parameter	Client's specification	Query from the Bidder	Response from the Purchaser
B	Fuel Tank Capacity	Minimum 70 Ltr	60 Ltr	The technical specifications provided in the bidding document are of a general nature and can be met by products from multiple manufacturers. Therefore, the proposed amendment to the technical specifications is not considered necessary. Accordingly, the bidder is requested to refer to and comply with the technical specifications specified in the bidding document.
C	Engine, Rated Output	31 kW, 42 HP	28 kW, 38 HP	



**MADAN BHANDARI
UNIVERSITY OF
SCIENCE AND TECHNOLOGY**

Acting Vice President, Admin and Finance